


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2019 / School / 2366

Dated: 24/12/2019

FIRE SAFETY CERTIFICATE

Certified that Mount Olivet Sr. Sec. School located at Street no. 100, B-Block, Sant Nagar, Burari, Delhi-84 comprised of 02 blocks- ground and 03 upper floors -interconnected) owned/ occupied by the Mount Olivet Sr. Sec. School have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 10.12.2019 in the presence of Mr. Birender Yadav, Principal and The premises have complied with requirements of circular issued by Director of Education letter no F.16/Estate/CC/Fire Safety/2011/3298-3798 dated 01.03.2011 and the building/ premise is fit for occupancy "Group B Educational" with effect from 24/12/19..... for a period of three years, in accordance with rule 36 unless under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010:


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25156707

Copy to :-

- 1 The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
- 2 The Manager, Mount Olivet Sr. Sec. School, Street no. 100, B-Block, Sant Nagar, Burari, Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

